

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7300-1132:101 Page 1 of 1

**CATEGORY:** Misc. Device/Control Unit Accessories

**LISTEE:** Electronic Systems USA, 9410 Bunsen Pkwy, Louisville, KY 40220  
Contact: \*Doug Kinney (414) 524-4358 Fax (414) 276-5979

**DESIGN:** Models UNITY and UNITY multi-user fire alarm monitoring systems. Suitable for providing automatic, manual, waterflow and sprinkler supervisory, central station and proprietary monitoring service. Refer to listee's data sheet for additional detailed product description and operational considerations. Basic system:

SY-UN-1XX-JZ	CPU-Main IRM Computer, Keyboard, Mouse, etc.
SY-UN-1XX-RM	CPU-Remote computer, Keyboard, Mouse, etc.
SY-UN-2XX	Color Monitor
SY-UN-4XX	Log Printer
SY-UN-396	Unity Backup RS-232 A/B Switching Box
SY-UN-922	Uninterruptable Power Supply
SY-UN-380	Short Haul Modem
LP-DC-018	Lighting Protector for Short Haul Modems
SY-UN-306	RS-232 to RS-485 Converter
SY-UN-980	Ethernet NIC
SY-UN-3XX	Digiboard Multi-Port Serial Communication Controller
SY-UN-921	Transient Voltage Surge Suppressor
Intel	Legacy Computer (p/n SY-UN-181)
IBM PS/2	Legacy Computer (p/n SY-UN-1XX)
TI-830	Legacy Printer (p/n SY-UN-3XX)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm monitoring system for use with separately listed compatible Honeywell Model "DeltaNet FS90 Plus" (CSFM No. 7170-1130:127), GS Building System's "EST IRC-3" (CSFM No. 7165-1388:151) or "EST FCC" (CSFM No. 7165-1388:106) fire alarm control unit.

**NOTE:**

1. Burglary and other non-fire functions were not examined.
2. Formerly 7165-1132:100 and 7170-1132:101

\*Rev. 06-05-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager